

^{*} No setback is required if structure is fire resistant per International Building Code & Fire Code [IBC & IFC].

^{**} Any building above 30 feet in height shall be subject to additional fire protection precautions per IBC & IFC.